



COUNTY OF DUPLIN
BUILDING INSPECTIONS DEPARTMENT
PO BOX 950
KENANSVILLE, NC 28349
PHONE: (910) 296-2124 FAX: (910) 296-2166

Temporary Power Form

Date _____ Power Co. _____

Job Address _____ City _____

Purpose For Power _____

Permit #'s: B _____, E _____, P _____, M _____

Power Requested For _____ 30 Days; _____ 60 Days; _____ 90 Days Max.

Before the authorization for temporary electrical power to the above structure, each contractor listed below has made a thorough inspection and check to ensure the electrical, mechanical, & plumbing systems in this structure are safely terminated or installed completely enough to the best of their ability to safely energize the electrical power for temporary use only as attested by their signatures below. Temporary power will be disconnected if the Certificate of Occupancy has not been issued within the time granted.

Owner Name: _____
Signature: _____

General Contractor: _____
Signature: _____

Electrical Contractor: _____
Signature: _____

Mechanical Contractor: _____
Signature: _____

Plumbing Contractor: _____
Signature: _____

This form does not exempt a final inspection by the Duplin County Building Inspection's Department for the issuance of a Certificate of Occupancy. By signing this form it is understood that failure to request a final inspection within the days granted is grounds for having power disconnected by authority of the Electrical Inspector who granted this approval.

Date of Inspection: _____ By: _____

NORTH CAROLINA ELECTRICAL CODE, 2008 EDITION

10.8 Temporary Power

10-8.1 Scope. The provisions of this section apply to the utilization of portions of the wiring system within a building to facilitate construction.

10.8.2 Provisions for Temporary Power. The Code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following, requirements have been met:

- 1) The service wiring and equipment, including, the meter socket enclosure, shall be installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized shall be complete and physically protected.
- 3) The grounding electrode system shall be complete.
- 4) The grounding and the grounded conductors shall be terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel shall be installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code apply.

10.8.3 Uses Prohibited. In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

10.8.4 Application for Temporary Power. Application for temporary power shall be made by and in the name of the applicant. The applicant shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, its intended use and duration.

10.8.5 Security and Notification. The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. The applicant shall alert personnel working in the vicinity of the energized electrical system to its presence.

10.9 Requirements of Other State Agencies, Occupational Licensing Boards, or Commissions.

The North Carolina State Building Codes do not include all additional requirements for building and structures that may be imposed by other State agencies, occupational licensing boards, and commissions. It shall be the responsibility of a permit holder, design professional, contractor, or occupational license holder to determine whether any additional requirements exist.